



CLEARANCES FOR INDOOR WATER METER W/ BACKFLOW PREVENTION INSTALLATION

METER SIZE	"A" MIN.	"B"		"C" MIN.	"D"	"E" PIPE DIA.	"F" MIN.	"G"
		MIN.	MAX.					
5/8"-3/4" METER	4'-0"	1'-4"	3'-0"	1'-4"	12 1/2"	3/4"	33 5/8"	7 3/4"
1" METER	4'-0"	1'-4"	3'-0"	1'-4"	17"	1"	38 1/4"	11"

Date: 3/02/2018

Standard Construction Drawing



Indoor Water Meter  
Residential Installation With  
Backflow Prevention

Drawing No.  
**WTR-11**