



STANDARD CLEARANCES FOR INDOOR WATER METER INSTALLATION

METER SIZE	"A" MIN.	"B"		"C" MIN.	"D"	"E" PIPE DIA.	"F" MIN.	"G"
		MIN.	MAX.					
5/8"–3/4" METER	4'–0"	1'–4"	3'–0"	1'–4"	12 1/2"	3/4"	12 3/8"	7 3/4"
1" METER	4'–0"	1'–4"	3'–0"	1'–4"	17"	1"	15 1/4"	11"

Date: 3/02/2018

Standard Construction Drawing



Indoor Water Meter
Residential Installation

Drawing No.
WTR-10