



TABLE FOR L (FEET)
 REQUIRED LENGTH OF RESTRAINED JOINTS
 D - DIAMETER OF PIPE

D	4"	6"	8"	10"	12"	16"	20"	24"
L	34	49	64	79	94	124	154	184

Date: 3/02/2018

Standard Construction Drawing



Restrained Joints
 Ductile Iron Pipe

Drawing No.
 WTR-19