



EARTH TRENCH
OUTSIDE OF PAVEMENT

NOTES

1. **BEDDING** SHALL BE ODOT TYPE 3 STRUCTURAL BACKFILL (#57 STONE) TO A DEPTH OF 1/8 OF THE PIPE DIAMETER, A MINIMUM OF 4 INCHES.
2. **HAUNCHING** SHALL BE ODOT TYPE 3 STRUCTURAL BACKFILL PLACED TO SPRINGLINE OF PIPE.
3. **INITIAL BACKFILL** SHALL BE ODOT TYPE 3 STRUCTURAL BACKFILL, PLACED 6 TO 12 INCHES OVER THE CROWN OF THE PIPE. INITIAL BACKFILL PROTECTS THE PIPE FROM FINAL BACKFILL.
4. **FINAL BACKFILL** MAY BE EXCAVATED MATERIAL WHICH IS FREE OF ROCKS, FROZEN GROUND. OR FOREIGN MATERIAL.

Date: 3/20/2018

Standard Construction Drawing



Typical PVC Waterline
Trench Detail

Drawing No.
WTR-26